

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL031017	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 07/21/2016
NAME OF PROVIDER OR SUPPLIER DAYSPRING OF WALLACE		STREET ADDRESS, CITY, STATE, ZIP CODE 4026 HIGHWAY 11 SOUTH WALLACE, NC 28466		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 000}	Initial Comments Report of Follow-up Survey by Frank Strickland 07/21/2016: Most of the cited deficiencies were field verified for correction. However, there is still one deficiency that requires action. Therefore, a new Plan of Correction is required.	{C 000}		
{C 101}	Existing Licensed Fac- No less than '71 Rules SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0301 APPLICATION OF PHYSICAL PLANT REQUIREMENTS The physical plant requirements for each adult care home shall be applied as follows: (2) Except where otherwise specified, existing licensed facilities or portions of existing licensed facilities shall meet licensure and code requirements in effect at the time of construction, change in service or bed count, addition, renovation, or alteration; however in no case shall the requirements for any licensed facility where no addition or renovation has been made, be less than those requirements found in the 1971 "Minimum and Desired Standards and Regulations" for "Homes for the Aged and Infirm", copies of which are available at the Division of Health Service Regulation at no cost; This Rule is not met as evidenced by: 1-Based on observations, this facility has not maintained the measures for the Special Locking (magnetic locks) on the exit doors as allowed by Section 1012.6 of the 1996 NC State Building Code. Section 1012.6.1. 4. F. requires, "If any required emergency release switch is of the locking type, all staff must carry emergency release switch keys."	{C 101}		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL031017	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 07/21/2016
NAME OF PROVIDER OR SUPPLIER DAYSPRING OF WALLACE		STREET ADDRESS, CITY, STATE, ZIP CODE 4026 HIGHWAY 11 SOUTH WALLACE, NC 28466		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 101}	Continued From page 1 Findings on 05/11/2016: The required emergency release switch located at each magnetically locked exit door was of the locking type with keyed switching that all staff in the SCU were not carrying. The med tech was the only staff member carrying a release switch key and the other staff that were interviewed carried no release switch keys. All staff who are responsible for the evacuation of the occupants must carry an emergency release key at all times when on duty.	{C 101}		